2020 Masters Exam Buster

Errata

The following five questions should be revised as follows! Editions sold after December 5th of 2020 were corrected prior to shipping!

generation cable located within cable trays outdoors? A. 8 feet B. 10 feet C. 6 feet D. 4.5 feet	
Q 17 said indoors at the end of the question. It should be "outdoors". Revise as shown.	
What is the minimum size grounding electrode conductor required for 3/O service conductors where the grounding electrode conductor will jump between building steel and two ground rods driven six feet apart in the earth? A. 1/O B. #4 C. #3	
D. #6 Q 40 had a #2 in answer B which was incorrect, it is a #4. Revise as shown.	
 How many #3 THHW conductors that are not compact can be installed in a piece of 2" EMT? A. 11 B. 12 C. 26 D. 16 Q118 Answer B had the incorrect answer of 18. The correct answer is B, 12 conductors. Revise as shown. 	
148) A commercial store with a 120/208 volt service, has 75,000 va of continuous loads, and 25,000 va of non continuous loads, what size overcurrent protection device will be required for the service conductors? A. 250 amps B. 300 amps C. 350 amps D. 400 amps	
148) 230.42 A / This question was amended on Dec 01 2020 due to an error 70,000 * 1.25 = 87,500 va 25,000 * 1 = 25,000 va Total = 112,500 va 112,500 / (208 * 1.73) = 312.5 amps 240.4B allows the next higher standard OCPD = 350 amps per Table 240.6A	
Q 148 was missing the correct voltage (120/208) and the solution key had a math error. Revise as shown. Change 75,000 to 70,000 in question.	

What size copper XHHW-2 conductor is required for a 250 amp electrical service installed at a dwelling rated 120/240 volt? The expected ambient temperature on the conductors will be 105 degrees Fahrenheit?

344)

A. 4/OB. 250 kcmilC. 3/OD. 350 kcmil

Q 344 Correct answer B. Revise as shown.